UNIT	CONDENSER	
MODEL #	LSC-1100E	SCALE NTS



DWG. # REV. WLETM3608-DRD-ST DATE 5/17/2024 SERIAL #

## NOTES:

- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS COIL SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING

**GVD DENOTES GROOVED** FLG DENOTES FLANGE

PE DENOTES PLAIN END


- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. 3/4" [19mm] DIA. MOUNTING HOLES. REFER TÓ RECOMMENDED STEEL SUPPORT DRAWING
- 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT IN [METRIC] [mm]
- 7. \* APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF CONNECTING PIPING

8. MAKE-UP WATER PRESSURE

20 psi [137 kPa] MIN, 50 psi [344 kPa] MAX







4'-9" \* [ 1448 ] (4) 4" [100] PE REFRIG IN 4'-9 5/8" [ 1464 ] (4) 4" [100] PE RÉFRIG OUT (2) ACCESS DOOR 2" [50] MPT (2) 3" [80] FPT MAKE-UP OVERFLOW 2'-7 1/2" [ 800 ] 2'-1/8" [ 613 ] 2'-7 3/4" [ 806 ] 3 5/8" [ 92 ] 3'-7 1/4" [ 1099 ] - 3" [80] MPT DRAIN 4'-1 7/8" [ 1267 ] 9'-9 3/4" —**-**FACE B

