UNIT	CONDENSER	
MODEL #	LSC-1100E	SCALE NTS



DWG. # WLETM3608-DRD-ST REV. SERIAL # DATE 5/18/2024

## NOTES:


- 1. (M)- FAN MOTOR LOCATION
- 2. HÉAVIEST SECTION IS COIL SECTION
- 3. MPT DENOTES MALE PIPE THREAD FPT DENOTES FEMALE PIPE THREAD BFW DENOTES BEVELED FOR WELDING

GVD DENOTES GROOVED

FLG DENOTES FLANGE PE DENOTES PLAIN END

- 4. +UNIT WEIGHT DOES NOT INCLUDE ACCESSORIES (SEE ACCESSORY DRAWINGS)
- 5. 3/4" [19mm] DIA. MOUNTING HOLES. REFER TO RECOMMENDED STEEL SUPPORT DRAWING
- 6. DIMENSIONS LISTED AS FOLLOWS: ENGLISH FT IN [METRIC] [mm]
- 7. \* APPROXIMATE DIMENSIONS DO NOT USE FOR PRE-FABRICATION OF CONNECTING PIPING
- 8. MAKE-UP WATER PRESSURE 20 psi [137 kPa] MIN, 50 psi [344 kPa] MAX

FACE C



4'-9" \* [ 1448 ] (4) 4" [100] PE REFRIG IN 4'-9 5/8" [ 1464 ] (4) 4" [100] PE RÉFRIG OUT (2) ACCESS DOOR 2" [50] MPT (2) 3" [80] FPT MAKE-UP OVERFLOW 2'-7 1/2" [ 800 ] 2'-1/8" [ 613 ] 2'-7 3/4" [ 806 ] 3 5/8" [ 92 ] 3'-7 1/4" [ 1099 ] - 3" [80] MPT DRAIN 4'-1 7/8" [ 1267 ] 9'-9 3/4" —**-**FACE B

